# **Technical Information**



2016-03-11 / 067-Aa

# Subject

Door Control TS 970 - New Software 1.2

## **Description**

The door control TS 970 (1) receives the software 1.2.

This software includes the following changes and enhancements.



## Commissioning of the control

After switching on the mains supply, the control runs in the query mode for about 5 seconds. During this time, the display rotates clockwise.

#### Emergency stop (terminal X3)

Applies to frequency converter drive units: Activation of the emergency stop is followed by a security phase, in which the control blocks the drive unit against restarting. This phase lasts for 30 seconds. During this time, the display rotates clockwise.

## Expansion of the status log

- In the future, the reaching of the final door positions will also be included in the records of the last 128 events (2).
- These records can be read and displayed on a smartphone or tablet pc via the GfA-Stick (❸ ⇒ part no.: 20003696) and the GfA+ App (4). Upon registration in the GfA-Portal (6), this information is available in unlimited quantities, permanently and for different door controls. Furthermore, by means of a search function in the GfA+ App, a search for available records pertaining to a serial number can also soon be made.

# **Figure**



### Notes

The new software will be incorporated in series production from March 2016. The described items are documented in the installation instructions.

